TI-IBR16-14IN

Issue 12



DCV4 Disc Check Valve

Description

The DCV⁴ stainless steel disc check valve is of the wafer pattern designed to be sandwiched between ASME flanges. It is suitable for use on a wide range of fluids for applications in process lines, hot water systems, steam and condensate systems etc.

Face-to-face dimensions conform to EN 558 part 2, series 52. As standard it will be supplied with a metal-to-metal seat for use on steam applications. Where it will be used on oil, air, gas and water applications, alternative seat material is available - see 'Optional extras'.

Optional extras

High temperature springs for temperatures up to 400°C.

Viton soft seats for oils, air and gas applications.

EPDM soft seats for water applications.

Standards

This product fully complies with the requirements of the Indian Boiler regulations, 1950.

Standard shut-off

Standard valves conform to EN 12266-1 rate E.

Valves conforming to EN 12266-1 rate D are available on request. Soft seated versions meet EN 12266-1 rate A, providing a differential pressure exists.

Certification

This product is available with certification to EN 10204 3.1. and IBR certification.

Note: All certification / inspection requirements must be stated at the time of order placement

Sizes and pipe connections


DN15, DN20, DN25, DN40, DN50, DN80 and DN100 Suitable for installation between ASME 150 or ASME 300 flanges.


Materials

No	. Part	Material	
1	Body	Austenitic stainless steel	ASTM A351 CF3M
2	Disc	Austenitic stainless steel	ASTM A276 316
3	Spring retainer	Austenitic stainless steel	BS 1449 316 S11
4	Standard spring	Austenitic stainless steel	BS 2056 316 S42
	High temp. spring	Nimonic 90	


Operation

Disc check valves are opened by the pressure of the fluid and closed by the spring as soon as the flow ceases and before the reverse flow occurs.





Pressure / temperature limits



The product **must not** be used in this region.

A-B-D High temperature spring and without spring. E-C-D Standard spring.

Please note: The figures displayed are only relevant when a metal-to-metal seat is used. If Viton or EPDM seats are used the product is restricted to the limits of the seat material chosen.

Body design conditions for saturated steam service ASME 300							
PMA	Maximum allov	wable pressure	49 b	oar g @ 37°C			
TMA	Maximum allov	wable temperature	400°0	C @ 29 bar g			
Minimu	ım allowable ter	nperature		-29°C			
РМО	Maximum oper for saturated s	49 b	oar g @ 37°C				
	Maximum operating temperature	Standard spring	300°C	@ 31.5 bar g			
ТМО		High temperature spring	400°	C @ 29 bar g			
		Without spring	400°0	C @ 29 bar g			
Minimum operating temperature -29°C Note: For lower operating temperatures consult Spirax Sarco							
Temperature limits		Viton seat -25°C to		°C to +205°C			
		EPDM seat	-40°	°C to +120°C			
Designed for a maximum cold hydraulic test pressure of 73.5 bar g							

Dimensions/weights (approximate) in mm and kg

	ASME 300	ASME 150					
Size	Α	В	С	D	E	F	Weight
DN15	54	47	38	25	22.35	15	0.24
DN20	67	57	46	31	27.35	20	0.41
DN25	73	67	54	35	33.15	25	0.54
DN40	95	86	76	45	49.15	40	1.15
DN50	111	105	95	56	59.15	50	1.84
DN80	149	136	130	71	90.15	80	3.69
DN100	181	174	160	80	111.15	100	5.70

K_V values

DN	15	20	25	40	50	80	100
K _V	4.4	7.5	12	26	39	84	150

For conversion: $C_V (UK) = K_V \times 0.963$ $C_V (US) = K_V \times 1.156$

Opening pressures in mbar

Differential pressures with zero flow for standard and high temperature springs.

→ Flow direction


DN	15	20	25	40	50	80	100
↑	25	25	25	28	29	31	33
→	22.5	22.5	22.5	24	24.5	25.5	26.5
↓	20	20	20	20	20	20	20

Where lowest opening pressures are required, valves without springs can be installed in vertical pipes with bottom-to-top flow.

Without spring

↑ 2.5 2.5	2.5	4.0	4.5	5.5	6.5
------------------	-----	-----	-----	-----	-----

Pressure loss diagram



Pressure loss diagram with open valve at 20°C. The values indicated are applicable to spring loaded valves with horizontal flow. With vertical flow, insignificant deviations occur only within the range of partial opening.

The curves given in the chart are valid for water at 20°C. To determine the pressure for other fluids the equivalent water volume flowrate must be calculated and used in the graph.

$$\mathring{V}_{\mathbf{W}} = \sqrt{\frac{\rho}{1000}} \times \mathring{V}$$

 \mathring{V} **w** = Equivalent water volume flow in I/s or m³/h Where:


= Density of fluid kg/m³

= Volume of fluid I/s or m³/h


Pressure loss information for steam, compressed air and gases is available from Spirax Sarco.

How to order

Example: 1 off Spirax Sarco DN40, DCV4 stainless steel disc check valve for fitting between ASME 300 flanges.




Centering dimension for ASME 300



Safety information, installation and maintenance

For full details see the Installation and Maintenance Instructions (IM-IBR16-15IN) supplied with the product.

DCV4 disc check valves must be fitted in accordance with the direction of flow arrow indicating correct fluid flow direction. When fitted with a spring they can be installed in any plane. When supplied without a spring they must be fitted in a vertical flow line with the flow from bottomto-top.



* Note: Flanges, bolts (or studs), nuts and joint gaskets are to be provided by the installer. Disc check valves are non-maintainable (no spares are available). Disc check valves are not suitable for use where heavily pulsating flow exists, such as close to a compressor.

Various options are denoted by a marking on the valve body:-

- High temperature spring Standard metal disc Without spring Standard metal disc 'N' 'W' Without spring .F. Standard spring Viton soft faced disc Standard spring EPDM soft faced disc 'WV Without spring Viton soft faced disc 'WE' Without spring EPDM soft faced disc
- Valves tested to EN 12266-1 Rate D

No identification indicates a standard spring with a metal disc.

Disposal

If a product which contains a Viton component has been subjected to a temperature approaching 315°C or higher, then it may have decomposed and formed hydrofluoric acid. Avoid skin contact and inhalation of any fumes as the acid will cause deep skin burns and damage to the respiratory system. Viton must be disposed of in a recognised manner as stated in the Installation and Maintenance Instructions (IM-IBR16-15IN). No other ecological hazard is anticipated with the disposal of this product providing due care is taken