

spirax sarco

Fig 14HP Carbon Steel Strainer

Description

The Fig 14HP is a carbon steel Y-type strainer designed to remove scale, rust and other debris from the pipeline.
 The standard stainless steel screen is 0.8 mm perforations.

Standards

This product fully complies with the requirements of the Indian Boiler Regulations, 1950.

Certification

The product is available with a manufacturer's Typical Test Report and IBR certification.

Note: All certification/inspection requirements must be stated at the time of order placement.

Sizes and pipe connections

1/4", 3/8", 1/2", 3/4", 1", 1 1/4" 1 1/2" and 2"
 Screwed BSP or NPT
 Socket weld ends to BS 3799 Class 3000 lb

Optional extras


Strainer screens

Stainless steel screen	Perforations	1.6 mm and 3.0 mm
	Mesh	40, 100 and 200
Monel screen	Perforations	0.8 mm and 3.0 mm
	Mesh	100


Blowdown or drain valve connections


The cap can be drilled to the following sizes to enable a blowdown or drain valve to be fitted at extra cost.

Strainer size	Blowdown valve	Drain valve
1/4", 3/8" and 1/2"	1/4"	1/4"
3/4" and 1"	1/2"	1/2"
1 1/4" and 1 1/2"	1"	3/4"
2"	1 1/4"	3/4"



Pressure/temperature limits



 The product **must not** be used in this region.

Body design conditions		ASME Class 800
PMA	Maximum allowable pressure	136.1 bar g @ 38°C
TMA	Maximum allowable temperature	425°C @ 76.7 bar g
Minimum allowable temperature		-10°C
PMO	Maximum operating pressure	136.1 bar g @ 38°C
TMO	Maximum operating temperature	425°C @ 76.7 bar g
Minimum operating temperature		-10°C
Note: For lower operating temperatures consult Spirax Sarco		
Designed for a maximum cold hydraulic test pressure of 205 bar g		

Materials

No. Part	Material
1 Body	1/4" and 1/2" Carbon steel ASTM A105N / 1.0460 3/4" to 2" Carbon steel ASTM A216 WCB / 1.0619 + N
2 Cap	Carbon steel ASTM A105N / 1.0460
3 Cap gasket	Reinforced exfoliated graphite
4 Strainer screen	Stainless steel A240 316L


K_V values

Size	¼"	⅜"	½"	¾"	1"	1¼"	1½"	2"
Perforations 0.8, 1.6 and 3 mm	1	2.6	3.6	11	15.5	26	41	68
Mesh 40 and 100	1	2.6	3.6	11	15.5	26	41	68
Mesh 200	1	2.6	2.6	9	13.0	21	35	55

For conversion: $C_V(\text{UK}) = K_V \times 0.963$ $C_V(\text{US}) = K_V \times 1.156$

Dimensions/weights (approximate) in mm and kg

Size	A	B	C	D	Screening area cm ²	Weight
¼"	70	51	80	32	27	0.43
⅜"	70	51	80	32	27	0.49
½"	73	52	81	32	27	0.56
¾"	90	64	100	36	43	0.72
1"	105	74	120	46	73	1.17
1¼"	140	102	164	60	135	2.35
1½"	152	115	184	70	164	3.30
2"	178	138	224	80	251	4.95



Spare parts

The spare parts available are shown in solid outline. Parts drawn in broken line are not supplied as spares.

Available spares


Strainer screen (state material, perforations or mesh and size of strainer)	4
Cap gasket (packet of 3)	3

How to order spares

Always order spares by using the description given in the column headed 'Available spares' and state the size and type of strainer and perforation or mesh required.

Example: 1 off Stainless steel strainer screen having 0.8 mm perforations for a ¾" Spirax Sarco Fig 14HP strainer.

Note: When replacing the strainer cap coat the thread only with anti-seize compound, making sure none gets on the gasket or gasket faces.



Safety information, installation and maintenance

For full details see the Installation and Maintenance Instructions (IM-IBR16-09IN) supplied with the product.

Warning:

The strainer cap gasket contains a thin stainless steel support ring, which may cause physical injury if not handled and disposed of carefully.



Disposal

The product is recyclable. No ecological hazard is anticipated with disposal of this product, providing due care is taken.

How to order

Example: 1 off Spirax Sarco 1½" Fig 14HP strainer having screwed BSP connections with a stainless steel screen having 0.8 mm perforations.

Recommended tightening torques

Item	Size	 or  mm	N m
2	¼", ⅜", and ½"	36 A/F	50 - 55
	¾"	38 A/F	60 - 66
	1"	50 A/F	100 - 110
	1¼"	46 A/F	180 - 200
	1½"	50 A/F	230 - 250
	2"	60 A/F	330 - 360