



DECLARATION OF CONFORMITY

According to Directive 2014/68/UE for a pressure equipment

The manufacturer: ZETKAMA Sp. z o.o. ul. 3 Maja 12, 57-410 Ścinawka Średnia, www.zetkama.com.pl

This declaration of conformity is issued under the sole responsibility of the manufacturer.
We hereby declare that bellows sealed stop valves listed below correspond to the Pressure Equipment Directive 2014/68/UE

Figure No. Connecting ends Shape	Material of Body	Nominal Diameter DN(mm)	Nominal Pressure PN(MPa)	Range of Working Temperature (°C)
234 Flanged ends Straight Pattern	Grey cast iron EN GJL250	32 ÷ 250	1,6	-10 ÷ 300
	Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
			2,5	
Cast steel GP240GH	32 ÷ 150	4,0	-20 ÷ 400	
235 Flanged ends Angle Pattern	Grey cast iron EN GJL250	32 ÷ 250	1,6	-10 ÷ 300
	Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
			2,5	
237 Welded ends Straight form	Cast steel GP240GH	32 ÷ 200	4,0	-20 ÷ 450
	Stainless steel GX5CrNiMo19-11-2	32 ÷ 200	4,0	-60 ÷ 400

Applied conformity assessment procedure: module H

The following harmonised standards have been applied: 1. EN-19; 2. EN-1515-4; 3. EN-1563; 4. EN-1092-1; 5. EN-10088-1; 6. EN-10213; 7. EN-12266-1; 8. EN-12516-2; 9. EN-12516-3; 10. EN-12516-4; 11. EN-13709; 12. EN-13789.

The other standards have been applied: 1. EN-558; 2. EN-1561; 3. EN-1092-2; 4. EN-10088-3; 5. EN-12266-2

Engaged Notified Body: Bureau Veritas S.A. No 0062 67/71 Boulevard de Chateau, 92200 Neuilly-sur-Seine, France

Surveillance of Quality Systems – Examination, inspections and tests during manufacturing

CE– Certificate of conformity No. CE-0062-PED–H-ZKM 001-16-POL

Declaration of conformity No. 2/09/2016

President of Board

General Director

Leszek Jurasz

Ścinawka Średnia 24.09.2016