


**INSTALLATION AND MAINTENANCE INSTRUCTIONS**

IM-8-603-US

December 2009

# TURBO-BAR



# Table of Contents

<b>Section 1: Product Introduction</b> .....	<b>4</b>	<b>Section 5: S-Turbo-Bar Flowmeter</b>	
Principle of Operation.....	4	<b>Electrical Installation</b> .....	<b>31</b>
General S-Turbo-Bar Flowmeter Features.....	5	General Information.....	31
S-600 Series Features.....	5	PA1 Preamplifier.....	31
S-700 Series Features.....	5	PA2 Preamplifier.....	31
S-900 Series Features.....	5	PAQ Preamplifier.....	31
<b>Section 2: Unpacking Your Flowmeter</b> .....	<b>6</b>	P2Q2 Preamplifier.....	31
Initial Inspection.....	6	Electronics Enclosures.....	31
Flowmeter Identification Plate.....	6	Wiring Recommendations.....	31
Calibration Data.....	6	Hum and Noise.....	31
EZ-Logic Interface Map.....	6	Ground Loops.....	31
<b>Section 3: Installation Guidelines</b> .....	<b>6</b>	PA1 Preamplifier.....	32
Ambient temperature Limit.....	6	Specifications: PA1.....	32
Straight Run Requirements.....	7	Wiring: PA1.....	32
Flowmeter Location.....	8	Junction Box Terminal Block Wiring: PA1.....	32
Nonvertical.....	9	PA2 Preamplifier.....	33
Flowmeter Alignment.....	9	Specifications: PA2.....	33
Overhead Clearance.....	9	Wiring: PA2.....	33
Easy Accessibility.....	9	Junction Box Terminal Block Wiring: PA2.....	33
Pipe Tapping.....	10	PAQ Preamplifier.....	35
S-600 Series.....	10	Specifications: PAQ.....	35
S-700 series.....	10	Wiring: PAQ.....	35
S-900 series.....	10	Junction Box Terminal Block Wiring: PAQ.....	35
<b>Section 4: Mechanical Installation</b> .....	<b>11</b>	Rescaling the PAQ.....	36
Hot Tap Installation: S-600.....	12	Zero and Span Adjustment: PAQ.....	37
Cold Tap Installation: S-600.....	12	P2Q2 Preamplifier.....	38
Insertion Depth Scale Reading Calculation: S-600.....	13	Junction Box Terminal Block Wiring: P2Q2.....	38
Rotor Orientation and Final Positioning: S-600.....	14	<b>Section 6: Optional S-TEM temperature</b>	
Dimensional Drawing: S-600.....	15	<b>Transmitter</b> .....	<b>39</b>
Cold Tap Installation: S-700.....	16	General Information.....	39
Installation for Flanged Connection.....	16	RTD.....	39
Installation for 2" NS-PT Connection: S-700.....	17	S-PTM1 Preamplifier.....	39
Insertion Depth Scale Reading Calculation: S-700.....	18	Zero and Span Adjustment: S-PTM1.....	40
Rotor Orientation and Final Positioning: S-700.....	19	<b>Section 7: Optional S-PT Pressure Transmitter</b> .....	<b>41</b>
Dimensional Outline: S-700.....	20	General Information.....	41
Hot Tap Installation: S-910/960.....	26	Wiring: S-PT.....	41
Cold Tap Installation: S-910/960.....	27	<b>Section 8: Equations and Definitions</b> .....	<b>42</b>
Insertion Depth Scale Reading Calculation:		General Information.....	42
S-TMP-910/960.....	28	Definitions.....	42
Rotor Orientation and Final Positioning:		Centerline vs. 1/4 Diameter Position:.....	42
S-910/960.....	29	Cal. Constant- Kf (pulses / ft).....	42
Dimensional Drawing: S-910/960.....	30	Obscuration Factor (Fo).....	42

---

Profile Factor (Fp) .....	42	Example 3 .....	48
System K-Factor (Ks) .....	42	Sample Application Information Sheet for	
Mathematical Equations Used to Find the Ks Value	42	Natural Gas.....	49
Liquid .....	42	Sample Rotor CalibrationSheet.....	50
Steam .....	42	<b>Section 9: Maintenance and Troubleshooting .....</b>	<b>51</b>
Natural Gas and Other Ideal Gases.....	43	General Information .....	51
Determining Flow Rate .....	43	No Output .....	51
Liquid Application Examples .....	44	Analog Output Equals 0 mA .....	52
Example 1 .....	44	Analog Output less than 4 mA.....	53
Example 2 .....	44	Inaccurate Output.....	53
Example 3.....	44	Normal Rotor .....	54
Sample Application Information Sheet for Water ....	45	Bent Blades .....	54
Steam Application Examples.....	46	Missing Rotor.....	54
Example 1 .....	46	Magnetized Rotor .....	55
Example 2 .....	46	OVERRANGED FLOWMETER .....	55
Sample Application Information Sheet for Steam ...	47	Chatter .....	55
Natural Gas Application Examples .....	48	<b>Section 10: Model and Suffix Codes.....</b>	<b>56</b>
Example 1 .....	48		
Example 2 .....	48		

---

# Section 1: Product Introduction

## 1.1 Principle of Operation

S-Turbo-Bar flowmeters measure volumetric flow rate of liquid, gas or steam by detecting the local velocity of a fluid stream within a pipe. This local velocity is converted to the average pipe velocity from the following equation:

$$V = V_l \cdot F_p$$

where:

$V$  = average pipe velocity

$V_l$  = local velocity

$F_p$  = profile factor

The profile factor accounts for the parabolic shape of a typical velocity profile in a pipe. It is derived from the Reynolds number of the flow.

The local velocity is determined by the frequency input generated by the turbine probe. The kinetic energy in the fluid stream causes the turbine to rotate at a frequency proportional to the local velocity. A magnetic pickup sensor is positioned near the spinning rotor so that as each blade tip passes underneath the pickup, the blade tip breaks the magnetic field and thus, generates a pulse. The frequency of this pulse is directly proportional to the local velocity.

Once the average velocity is calculated from the local velocity, the volumetric flow rate can then be determined from the following equation:

$$Q = V \cdot A$$



where:

$Q$  = volumetric flow rate

$V$  = average velocity

$A$  = unobstructed cross sectional area of the pipe


Microprocessor electronics provide a frequency or 4-20 mA output proportional to the flow rate. Locally displayed flow rate and total, in user selectable engineering units, are available options.



## 1.2 General S-Turbo-Bar Flowmeter Features

S-Turbo-Bar flowmeters offer:

- Smart transmitter/ HART® Protocol compatibility
- Simultaneous 4–20 mA and frequency outputs
- Negligible pressure loss
- Interchangeable rotors for a wide variety of applications
- Optional, integral pressure and/or temperature transmitters



### 1.3 S-TMP-600 Series Features

- Line sizes from 3 to 20" (80 to 500 mm)
- Line pressures up to 125 psig (8.62 barg)
- temperature range from -40 to 400 °F (-40 to 204 °C)
- Hot tappable
- Bronze isolation valve included
- Retractable using screw thread rising stem design
- Mounting: 2" NS-PT with thread-o-let
- Integral scale for accurate sensor positioning

### 1.4 S-TMP-700 Series Features

- Line sizes from 3 to 78" (80 to 1980 mm)
- Line pressures up to 5000 psig (345 barg)
- temperature range from -200 to 600 °F (-129 to 316 °C)
- Not hot tappable
- Mounting: 2" NS-PT or 2" raised face 150#, 300#, 600# or 900# ANSI flanges

### 1.6 S-TMP-900 Series Features

- Line sizes from 3 to 80" (80 to 2000 mm)
- Line pressures up to 900# flange rating
- temperature range from -200 to 752 °F (-129 to 400 °C)
- Hot tappable with 2" isolation valve
- Retractable using ACME, non-rising stem
- All stainless steel construction
- Integral scale for accurate sensor positioning
- Mounting: 2" raised face 150#, 300#, 600# or 900# ANSI flanges

## Section 2: Unpacking Your Flowmeter

### 2.1 Initial Inspection

Upon receiving your Spirax Sarco equipment, verify that all materials on the packing list are present. Check for possible shipping damage, and notify the freight carrier or your Spirax Sarco representative if any has occurred.

### 2.2 Flowmeter Identification Plate

A permanent identification plate is attached to your S-Turbo-Bar flowmeter. This plate contains information on model, serial/W.O., date, pressure, temperature, and TAG# (if supplied by customer). Verify that this information is consistent with your metering requirements. Model and suffix codes are listed in Section 10, p. 56.

<b>S-TURBO-BAR™</b> INSERTION TURBINE FLOWMETER		↑ FIELD WIRING ↑ ↓ ELECTRONICS ↓	<b>spirax / sarco®</b> 1150 NORTHPOINT BLVD., BLYTHEWOOD, SC 29016	MADE IN U.S.A. 463009 D
MODEL No.:	OUTPUT:			
TAG No.:	MWP: _____ PSI@100° F			
SERIAL/W.O. No.:	FLANGE RATING:			
DATE CODE:	K FACTOR:			
MADE IN USA ⚡ CAUTION: OPEN CIRCUIT BEFORE REMOVING EITHER COVER ⚡	SUPPLY: 24 VDC NOM, 42 VDC MAX AT 35 mA MAX PROCESS TEMP 752° F (400° C)	46016-1-A		

**Identification Plate for S-Turbo-Bar Flowmeters with EZ-Logic™ Electronics**

**Identification Plate for S-Turbo-Bar Flowmeters with All Other Electronics**

### 2.3 Calibration Data

Save the rotor calibration and application information data sheets when unpacking your new S-Turbo-Bar flowmeter. These data sheets are important in setting up and monitoring the performance of your new flowmeter.

### 2.4 EZ-Logic Interface Map

If your S-Turbo-Bar flowmeter is equipped with the optional EZ-Logic™ Electronics, an EZ-Logic™ Interface Map is included with your flowmeter. This map shows how the flowmeter has been programmed at the factory. If your application changes, contact your representative for an updated map.


## Section 3: Installation Guidelines

Choosing the proper installation location for your S-Turbo-Bar flowmeter involves several important considerations:

### 3.1 Ambient temperature Limit

The S-Turbo-Bar electronics are designed to function in a maximum continuous ambient temperature of 140 °F (60 °C). Flowmeters exposed to ambient temperatures above this level for extended periods of time are subject to a shortened operating life and may not be covered under the Spirax Sarco warranty.

If ambient temperatures exceed 140 °F (60 °C), electronics can be remote mounted with the EZ-Logic™ Electronics option. There are two remote mount options: Pipe Mount and Wall Mount. The maximum cable length between flowmeter and remote mount electronics is fifty (50) feet or fifteen (15) meters.






**NOTE:** The straight run of pipe must have the same nominal diameter as the flowmeter body.


### 3.2 Straight Run Requirements

The installation location should be selected to minimize possible turbulence and swirl. In general, the minimum unobstructed run of straight pipe is ten (10) pipe diameters upstream and five (5) pipe diameters downstream. The extent of flow disturbances depends upon piping configuration. Valves, elbows, control valves and other piping components may add disturbances to the flow. If such conditions exist and/or sufficient straight pipe is unavailable, a flow conditioner may be used to improve measurement conditions. The minimum straight run requirements for different piping configurations are shown below.



### 3.3 Flowmeter Location

The flowmeter can be mounted in either horizontal or vertical piping runs. It is important for the pipe to be full for accurate measurements. Follow the guidelines below for recommended flowmeter locations.






### 3.4 Nonvertical

If nonvertical mounting is required, the deviation from vertical should not exceed  $90^\circ$ . When the flowmeter is mounted beyond  $90^\circ$ , condensate may drip into the condulets (electronics enclosures), causing a short in the flowmeter's electronics. Also, the isolation valve may trap steam or hazardous chemicals, presenting a danger to persons servicing the flowmeter. The flowmeter should always be self-draining.

### 3.5 Flowmeter Alignment

The flowmeter's turbine sensor must be correctly aligned to the perpendicular axis to avoid measurement errors.



### 3.6 Overhead Clearance


A minimum of 12" of overhead clearance is recommended for ease of installation.

### 3.7 Easy Accessibility

The installation location should be where the flowmeter will be easy for workers to safely and conveniently access all parts of the flowmeter.

### 3.8 Pipe Tapping


The pipeline should be prepared for either cold tap or hot tap installations. A cold tap installation involves drilling a hole into a pipeline that has been depressurized and for which service has been shutdown. A hot tap installation involves drilling a hole into a pressurized line without line shutdown and disruption of the process.




#### 3.8.1 S-TMP-600 Series

The S-TMP-600 series can be hot tapped. A mounting kit, which includes a 2" bronze isolation valve, a pipe nipple and a thread-o-let, are standard with each flowmeter.

#### 3.8.2 S-TMP-700 series



The S-TMP-700 series can not be hot tapped; it can only be installed and removed with process shutdown because it uses a Swagelok® fitting and is nonretractable. There are two mounting connections: 2" NS-PT and flanged. The 2" NS-PT connection requires a 2" thread-o-let for installation. The flanged connection requires a 2" weld-o-let and a 2" raised face, weldneck flange with the same pressure rating as the flowmeter flange. These mounting connections are not included with the flowmeter, but may be ordered separately.



#### 3.8.4 S-TMP-900 series

The S-TMP-900 series can be hot tapped. Installation requires a 2" weld-o-let and a 2" raised face, weldneck flange with the same pressure rating as the flowmeter flange. A 2", double flanged, fully ported ball or gate valve that adheres to the dimensions shown may be used as the isolation valve. These mounting connections are not included with the flowmeter, but may be ordered separately.



**CAUTION:** Hot tapping must be performed by a trained professional.

Local state regulations often require a hot tap permit. The manufacturer of the hot tap equipment and/or the contractor performing the hot tap is responsible for providing proof of such permit.

## Section 4: Mechanical Installation

### 4.1 Hot Tap Installation: S-TMP-600

The S-TMP-600 can be installed without process shutdown or line depressurization. The S-TMP-600 is shipped with an isolation valve and a pipe nipple attached to the flowmeter. For a hot tap installation, the isolation valve and pipe nipple need to be separated from the flowmeter.

**Step 1.** Weld thread-o-let to pipe.

**Step 2.** Thread 2" pipe nipple into thread-o-let. Hand tighten.


**Step 3.** Thread 2" bronze, isolation valve to pipe nipple. Attach hot tap tool. Fully open isolation valve. Hot tap pipe. Hole should be 1.875" in diameter, 2" for extended stem models. Retract hot tap tool. Close isolation valve. Remove hot tap tool.

**Step 4.** Attach tap check tool to the end of the flowmeter stem before proceeding.

Thread flowmeter into isolation valve. Verify that 1/4" bleed valve is closed. Open isolation valve. Turn the retractor handle to insert tap check tool into pipe and then, retract tap check tool completely. Close isolation valve. Slowly open bleed valve to bleed off the trapped fluid inside the isolation valve and flowmeter assembly. Remove flowmeter from isolation valve. Inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

**Step 5.** Remove tap check tool and attach turbine sensor (rotor assembly) to end of stem. Verify that screw and safety wire on rotor assembly are properly installed.

Thread flowmeter into isolation valve. Use Teflon tape or PST on threads to improve seal and to prevent seizing. Verify that bleed valve is closed. Fully open isolation valve. If the flowmeter is supplied with a pressure transmitter, open bleed valve. Do not insert turbine sensor into pipe until calculating the insertion depth, p. 13.



#### 4.2 Cold Tap Installation: S-TMP-600

Process shutdown and line depressurization are required for cold tap installation.

**Step 1.** Tap pipe. Hole should be 1.875" in diameter (2" for extended stem models).


**Step 2.** Weld thread-o-let to pipe.

**Step 3.** Attach tap check tool to the end of the flowmeter stem before proceeding.

Thread flowmeter to thread-o-let. Verify that 1/4" bleed valve is closed. Open 2" bronze isolation valve. Turn the retractor handle to insert tap check tool into pipe and then, retract tap tool completely. Remove flowmeter from thread-o-let and inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

**Step 4.** Remove tap check tool and attach turbine sensor (rotor assembly) to end of flowmeter stem. Verify that screw and safety wire on rotor assembly are properly installed.

Thread flowmeter to thread-o-let. Use Teflon tape or PST on threads to improve seal and to prevent seizing. Verify that bleed valve is closed. Fully open isolation valve. If the flowmeter is supplied with a pressure transmitter, open bleed valve. Do not insert turbine sensor into pipe until calculating the insertion depth, p. 13.





**NOTE:** The distance the fully retracted rotor travels before becoming visible has been figured into the factory adjustment of the depth scale.

### 4.3 Insertion Depth Scale Reading Calculation: S-TMP-600

After tapping the pipe and installing the S-TMP-600, the turbine sensor needs to be properly positioned within the pipe. To determine the proper insertion depth, the scale reading must be calculated. The scale reading is the figure that the top of the cursor should be set to on the depth scale. Use the proper side of the scale depending on the rotor style. The 150 series (1.5") uses the left side of the scale; the 100 series (1") uses the right side.

Refer to the figure below and use the following equation to calculate the insertion depth:

$$\text{Scale Reading} = I + E + Wt$$

Where:

$I$  = For pipe sizes less than 12", inside pipe diameter  $\div$  2

$I$  = For pipe sizes 12" and larger, inside pipe diameter  $\div$  4

$E$  = Distance from the top of the stem housing to the outside pipe wall. This distance varies depending on how tightly the pipe nipples are screwed into the isolation valve and thread-o-let.

$Wt$  = Thickness of the pipe wall. The disk cut-out or "coupon" from the tapping procedure can be measured, or this number can also be obtained from a piping handbook.

Example:

A S-TMP-600 is to be installed on a 12" schedule 40 pipe. The following measurements have been obtained:


$$I = (11.938 \div 4) = 2.98"$$

$$E = 12.5"$$

$$Wt = 0.375"$$

$$\text{Scale Reading} = I + E + Wt$$

$$\text{Scale Reading} = 2.98" + 12.5" + 0.375" = \mathbf{15.855"}"$$






**CAUTION:** Do not allow the orientation of the flowmeter or the insertion depth to change after insertion is complete. A change in insertion depth or alignment will cause inaccurate readings and shortened rotor life.

**4.4 Rotor Orientation and Final Positioning: S-TMP-600**


Use the retractor handle to carefully insert the rotor down into the pipe until the calculated insertion depth figure on the depth scale lines up with the top of the cursor.

Use a pipe wrench to align the retractor bar assembly so the flow direction arrow on the cursor is in line with the pipe and pointed downstream.


Lock the stem in position by tightening the orientation set screw.




4.5 Dimensional Drawing: S-TMP-600



Insertion Depth		Weight
Minimum	Maximum	Maximum
4.5" (114 mm)	18" (457 mm)	28 lbs. (12.7 kg)




**Pipe Mount Electronics**



30' Cable (9.144 m) and U-bolts supplied. **Note: Cable must be run in conduit (not supplied). Conduit connection is 3/4" NPT (PG 13.5).**

**OR**

**Wall Mount Electronics**



#### 4.6 Cold Tap Installation: S-TMP-700

The S-TMP-700 is nonretractable and must be cold tapped. Process shutdown and line depressurization are required for cold tapping. There are two mounting connections available: Flanged or 2" NS-PT.

##### 4.6.1 Installation for Flanged Connection

**Step 1.** Tap pipe. Hole should be 1.875" in diameter (2" for extended stem models).

**Step 2.** Weld weld-o-let to pipe.


**Step 3.** Weld weldneck flange to weld-o-let.

**Step 4.** Attach tap check tool to the end of the flowmeter stem before proceeding.

Attach flowmeter to flange. Verify that 1/4" bleed valve is closed. Use orientation levers to manually lower tap check tool into pipe and then, retract tap check tool completely. Remove flowmeter from flange and inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

**Step 5.** Remove tap check tool and attach turbine sensor (rotor assembly) to end of flowmeter stem. Verify that screw and safety wire on rotor assembly are properly installed.

Reconnect flowmeter to flange. Verify that 1/4" bleed valve is closed. If the flowmeter is supplied with a pressure transmitter, open 1/4" bleed valve. Do not lower turbine sensor into pipe until calculating insertion depth, p. 18.





#### 4.6.2 Installation for 2" NS-PT Connection: S-TMP-700

**Step 1.** Tap pipe. Hole should be 1.875" in diameter (2" for extended stem models).


**Step 2.** Weld thread-o-let to pipe.

**Step 3.** Attach tap check tool to the end of the flowmeter stem before proceeding.

Thread flowmeter to thread-o-let. Verify that 1/4" bleed valve is closed. Use orientation levers to manually lower tap check tool into pipe and then, retract tap tool completely. Remove flowmeter from thread-o-let and inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

**Step 4.** Remove tap check tool and attach turbine sensor (rotor assembly) to end of flowmeter stem. Verify that screw and safety wire are properly installed.

Reconnect flowmeter to thread-o-let. Verify that 1/4" bleed valve is closed. Use Teflon tape or PST on threads to improve seal and prevent seizing. If the flowmeter is supplied with a pressure transmitter, open 1/4" bleed valve. Do not lower turbine sensor into pipe until calculating insertion depth, p. 18.



#### 4.7 Insertion Depth Measurement Calculation: S-TMP-700

After tapping the pipe and installing the S-TMP-700, the turbine sensor needs to be properly positioned within the pipe. To determine the proper insertion depth, the insertion depth must be calculated. Refer to the figures below and use the following equation to calculate the insertion depth:

$$B = C - I - E - Wt$$

Where:

$B$  = Installed dimension to be set on the flowmeter

$C$  = For 100 series (1") rotors, 14.25"

$C$  = For 150 series (1.5") rotors, 14.50"

$I$  = For pipe sizes less than 12", inside pipe diameter  $\div$  2

$I$  = For pipe sizes 12" and larger, inside pipe diameter  $\div$  4

$E$  = Distance from the raised face of the flange or top of NS-PT fitting to the outside pipewall

$Wt$  = Thickness of the pipe wall. The disk cut-out or "coupon" from the tapping procedure can be measured, or this number can also be obtained from a piping handbook.

Example:

A S-TMP-700 with a 100 series rotor is to be installed on a 12" schedule 40 pipe. The following measurements have been obtained:

$C$  = 14.25"


$I$  = (11.938"  $\div$  4) = 2.98"

$E$  = 4.5"

$Wt$  = 0.406"

$$B = C - I - E - Wt$$

$$B = 14.25" - 2.98" - 4.5" - 0.406" = \mathbf{6.364"}$$





**CAUTION:** Do not force stem into pipe. If the stem insertion is blocked, retract and remove the flow-meter from the pipe line, checking to make sure the opening conforms with the guidelines listed in the mounting guidelines.




**NOTE:** Once the fitting has been tightened, the stem position becomes permanent and cannot be changed. Verify insertion depth prior to final tightening of the fitting.

#### 4.8 Rotor Orientation and Final Positioning: S-TMP-700


Manually insert the stem into the pipe until the calculated insertion depth is obtained.

Align the rotor by using the orientation levers so that the flow direction arrow is parallel to the pipe and pointed downstream..

Lock the stem in position by tightening the Swagelok® fitting. Verify insertion depth prior to final tightening of the fitting. Once the fitting has been tightened, the stem position becomes permanent and cannot be changed.



4.9 Dimensional Outline: S-TMP-700





**CAUTION:** Hot tapping must be performed by a trained professional.

Local state regulations often require a hot tap permit. The manufacturer of the hot tap equipment and/or the contractor performing the hot tap is responsible for providing proof of such permit.


#### 4.15 Hot Tap Installation: S-TMP-910/960

The S-TMP-910/960 can be installed without process shutdown or line depressurization.

- Step 1. Weld weld-o-let to pipe.
- Step 2. Weld pipe nipple into weld-o-let.
- Step 3. Weld flange to pipe nipple.
- Step 4. Attach isolation valve to flange. Attach hot tap tool. Open isolation valve. Hot tap pipe. Hole should be 1.875" in diameter (2" for extended stem models). Retract hot tap tool. Close isolation valve. Remove hot tap tool.
- Step 5. Attach tap check tool to the end of the flowmeter stem before proceeding.

Attach flowmeter to isolation valve. Verify that 1/4" bleed valve is closed. Open isolation valve. Turn wheel to insert tap check tool into pipe and then, retract tap tool completely. Close isolation valve. Slowly open bleed valve to bleed off the trapped fluid inside the isolation valve and flowmeter assembly. Remove flowmeter from isolation valve and inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

- Step 6. Remove tap check tool and attach turbine sensor (rotor assembly) to end of flowmeter stem. Verify that screw and safety wire on rotor assembly are properly installed. Reconnect flowmeter to isolation valve. Verify that 1/4" bleed valve is closed. Fully open isolation valve. If the flowmeter is supplied with a pressure transmitter, open 1/4" isolation valve. Do not lower turbine sensor into pipe before calculating the proper insertion depth.



#### 4.16 Cold Tap Installation: S-TMP-910/960

Process shutdown and line depressurization are required for cold tapping.

Step 1. Tap pipe. Hole should be 1.875" in diameter (2" for extended stem models).

Step 2. Weld weld-o-let to pipe.

Step 3. Attach pipe nipple to weld-o-let.


Step 4. Attach flange to pipe nipple.

Step 5. Attach tap check tool to the end of the flowmeter stem before proceeding.

Attach flowmeter to flange. Verify that 1/4" bleed valve is closed. Turn wheel to insert tap check tool into pipe and then, retract tap tool completely. Remove flowmeter from flange and inspect tap check tool for damage. If any has occurred, check installation for clearance problems.

Step 6. Remove tap check tool and attach turbine sensor (rotor assembly) to end of flowmeter stem. Verify that screw and safety wire on rotor assembly are properly installed.

Verify that 1/4" bleed valve is closed. Reconnect flowmeter to flange. If the flowmeter is supplied with a pressure transmitter, open bleed valve. Do not lower turbine sensor into pipe before calculating the proper insertion depth.





**NOTE:** The distance the fully retracted rotor travels before becoming visible has been figured into the factory adjustment of the depth scale.

#### 4.17 Insertion Depth Scale Reading Calculation: S-TMP-910/960

After tapping the pipe and installing the S-TMP-910/960, the turbine sensor needs to be properly positioned within the pipe. To determine the proper insertion depth, the scale reading must be calculated.

The scale reading is the figure that the cursor should be set to on the depth scale. Use the proper arrow depending on the rotor style. The 150 series (1.5") uses the bottom arrow; the 100 series (1") uses the top arrow.

Refer to the figure below and use the following equation to calculate the proper insertion depth:

$$\text{Scale Reading} = I + E + Wt$$

Where:

$I$  = For pipe sizes less than 12", inside pipe diameter  $\div 2$

$I$  = For pipe sizes 12" and larger, inside pipe diameter  $\div 4$

$E$  = Distance from the top of the isolation valve to the outside pipe wall.

$Wt$  = Thickness of the pipe wall. The disk cut-out or "coupon" from the tapping procedure can be measured, or this number can also be obtained from a piping handbook.

Example:

A S-TMP-910/960 is to be installed on a 12" schedule 40 pipe. The following measurements have been obtained:


$$I = (11.938 \div 4) = 2.98"$$

$$E = 12.5"$$


$$Wt = 0.375"$$


$$\text{Scale Reading} = I + E + Wt$$

$$\text{Scale Reading} = 2.98" + 12.5" + 0.375" = \mathbf{15.855"}"$$



Section 4

 **NOTE:** *Torquing the nuts above the packing gland over 25 ft-lbs could damage the stem or stem housing.*

 **CAUTION:** *Do not allow the orientation of the flowmeter or the insertion depth to change after insertion is complete. A change in insertion depth or alignment will cause inaccurate readings and shortened rotor life.*


**4.18 Rotor Orientation and Final Positioning: S-TMP-910/960**

1. Carefully insert the rotor into the pipe until the calculated scale reading on the depth scale lines up with the arrow on the retractor bar assembly.

If the rotor is a 1.5" size (series 150), line up the bottom arrow on the retractor bar assembly marked 1.5 with the depth scale as shown above.

If the rotor is a 1.0" size (series 100), line up the top arrow on the retractor bar assembly marked 1.0 with the depth scale as shown above.

2. Align the rotor by using the orientation lever so the flow direction arrow is in line with the pipe and pointed downstream.
3. Tighten the nuts above the packing gland to stop leakage around stem. Do not torque the nuts over 25 ft-lbs.
4. Lock the stem in position by tightening the orientation lock screw.






4.19 Dimensional Drawing: S-TMP-910/960

Stem Length	Retractor Length (Dim. A)	Insertion Depth* (Dim. B)
Standard	30" (762 mm)	20" (508 mm)
1' Extended	42" (1067 mm)	32" (813 mm)
2' Extended	54" (1372 mm)	44" (1120 mm)

\* Minimum insertion depth is 1.5" (38 mm)

Connection	Weight**
2" 150#	30 lbs (13.6 kg)
2" 300#	35 lbs (15.8 kg)
2" 600#	40 lbs (18.1 kg)
2" 900#	47 lbs (21.3 kg)



\*\* Add 5 lbs (2.3 kg) for each additional foot of retractor length



Pipe Mount Electronics

OR

Wall Mount Electronics



30' Cable (9.144 m) and U-bolts supplied. **Note: Cable must be run in conduit (not supplied). Conduit connection is 3/4" NPT (PG 13.5).**

## Section 5: S-Turbo-Bar Flowmeter Electrical Installation

### 5.1 General Information

The S-Turbo-Bar electronics are preamplifiers, designed to amplify and convert the raw coil output to a square wave pulse or 4-20 mA signal. The available S-Turbo-Bar preamplifiers are:

### 5.2 Wiring Recommendations

Proper wiring is essential to achieving satisfactory electronic performance. The following is recommended:

1. Always use shielded cable.
2. Select the proper wire gauge. The recommended wire gauge is 18 to 22 AWG.
3. Do not exceed a distance of 6000 feet between the preamplifier and receiving electronics.

#### 5.2.1 Hum and Noise

The maximum run length may be limited due to hum and noise pickup along the cable. In most cases, a properly shielded and grounded cable limits this noise interference and allows accurate data transmission.

In cases where heavy electrical machinery is present, however, strong noise fields are generated, which may interfere with signal transmission. In such conditions, the shielded cable should be run through grounded electrical conduit to provide extra shielding.

#### 5.2.2 Ground Loops

Ground loops may interfere with signal transmission by superimposing unwanted signals on the desired signal. This may be prevented by correctly connecting the cable shields. How the shield should be connected depends on whether a metal or plastic pipeline is being used.

**Metal Pipelines:** Metal pipelines are usually earth grounded. Thus, the cable shield should not be connected at the flowmeter. The shields should be connected to the AC ground terminal at the power supply.

**Plastic Pipelines:** Plastic pipelines require the transmitter conduit to be connected to an earth ground. To do so, connect the signal cable shield to the conduit via one of the S-Turbo-Bar's junction box screws. Also, the shield from each transducer cable should be connected to the AC ground terminal at the power supply.

**Note:** See EZ Logic™/Hart Instruction and Operation manual for S-Turbo-Bar for electrical installation.

## Section 6: Optional S-TEM temperature Transmitter

### 6.1 General Information

The S-TEM is a platinum resistance temperature sensor (RTD). This unit is used to measure the temperature of process fluids. The S-TEM is highly repeatable and has exceptional resistance stability with respect to temperature. The S-TEM may be selected with a direct RTD, or resistance, output or with a 4-20 mA analog output.

The 4-20 mA analog output includes a preamplifier, which is factory scaled and calibrated to one of several standard temperature ranges (Fahrenheit or Celsius).


The S-TEM can be integrally mounted to a S-Turbo-Bar flowmeter at the factory. Like the S-Turbo-Bar flowmeter electronics, it is housed in an explosion proof conduit using two screws and a standoff. Alternatively, the S-TEM can be mounted separately from the S-Turbo-Bar flowmeter in a thermowell to allow installation and removal without process shutdown.

### 6.2 RTD

The RTD is factory prewired to the S-TEM sensor. No wiring to the S-TEM itself is required. The RTD has three (3) working terminals. They are:

- Terminal A is the single RTD lead.
- Terminals B and C are the two common RTD leads.

Use a screw driver or similar tool to open the S-TEM conduit to access the RTD terminal block. Connect the RTD to receiving electronics as shown below.



### 6.3 S-PTM1 Preamplifier

The S-TEM sensor is factory prewired to the S-PTM1 preamplifier. No wiring to the S-TEM itself is required. The preamplifier is factory prewired to the junction box terminal strip. No wiring to the PTM1 preamplifier is required. There are four (4) terminals on the PTM1 preamplifier. The factory wiring is:

- Terminals 1 and 5 are the RTD terminals. The leads from the S-TEM are connected to these terminals.
- Terminal 3 is the supply voltage terminal. It is connected to terminal 5 of the junction box terminal block.
- Terminal 4 is the return 4-20 mA signal. It is connected to terminal 2 of the junction box terminal block.

**6.3.1 Zero and Span Adjustment: PTM1**


The PTM1 preamplifier is factory calibrated for optimum performance. The zero and span potentiometers may only be adjusted to fine tune or to recalibrate the PTM1. To adjust the zero and span:

1. Disconnect the factory wiring at the PTM1 terminals that connect the PTM1 preamplifier and the junction box terminal block.
2. Use a 24 VDC power supply, precision R-box and digital multimeter. Make the connections shown below.
3. Refer to the S-TEM calibration data supplied with the S-Turbo-Bar flowmeter. A copy of the calibration data is also inside the PTM1 conduit. For example:

Calibration Data:

4.00 mA:	32 °F	=	1000.00 Ω
8.00 mA:	41 °F	=	1019.03 Ω
12.00 mA:	50 °F	=	1038.04 Ω
16.00 mA:	59 °F	=	1057.02 Ω
20.00 mA:	68 °F	=	1075.96 Ω

4. Set the R-box to zero scale (4 mA), according to the resistance value in the calibration data. Turn the zero adjustment potentiometer until the output reads  $4 \pm 0.016$  mA.
5. Set the R-box to full-scale (20 mA), according to the resistance value on the calibration data. Turn the span adjustment potentiometer until the output reads  $20 \pm 0.016$  mA.
6. Because the span adjustment affect zero point, steps 3 and 4 must be repeated until the readings are within  $\pm 0.016$  of zero scale and full scale.
7. Reconnect the cables from the junction box terminal block to the PTM1 preamplifier. Refer to the factory wiring listed under 6.2 PTM1 Preamplifier, p. 39.



## Section 7: Optional S-PT Pressure Transmitter

### 7.1 General Information

The S-PT is a two (2) wire pressure transmitter. This unit is used to measure the pressure of process fluids. Process pressure is applied to an isolating diaphragm, which displaces the sensing capacitor. The S-PT takes advantage of the large capacitance signal generated by an extremely small amount of motion. This high signal level simplifies the electronics. Because the amplifier circuit has few components and operates at low gain, overall transmitter reliability is maximized.


The S-PT can be integrally mounted to a S-Turbo-Bar flowmeter at the factory.

### 7.2 S-PT Wiring

The S-PT is factory prewired to the junction box terminal block. No wiring to the S-PT itself is required. The S-PT has two (2) terminals: positive (+) and negative (-).

- The positive (+) terminal is connected to terminal 5 on the junction box terminal block (blue wire).
- The negative (-) terminal is connected to terminal 1 on the junction box terminal block (red wire).

Refer to the specific electronic preamplifier (PA1, PA2, PAQ, P2Q2) wiring diagram to connect the 4-20 mA pressure output to receiving electronics.



## Section 8: Equations and Definitions

### 8.1 General Information

This section describes definitions and equations necessary for understanding the setup of the S-Turbo-Bar flowmeter and electronics. Referring to the application information sheet supplied with your S-Turbo-Bar flowmeter, note the terms and definitions described below. A sample application information sheet is shown on page 45.

### 8.2 Definitions

#### 1. Centerline vs. 1/4 Diameter Position:

Depending on pipeline diameter, the rotor is positioned at either centerline (1/2 of the pipe internal diameter) or 1/4 of the pipe internal diameter. For pipe sizes less than 12", the centerline position should be used. For pipe sizes 12" and larger, the 1/4 diameter position should be used.

#### 2. Cal. Constant- Kf (pulses/ ft):

All Spirax Sarco rotors are individually calibrated to determine the rotor calibration constant (Kf). Each rotor is supplied with its own calibration sheet. This sheet will include the frequency/velocity pairs used to determine the Kf of each calibration point, the mean Kf and the percent deviation from the best linear fit. A sample rotor calibration sheet is shown on page 50.

#### 3. Obscuration Factor (Fo):

The obscuration factor (Fo) is found on the Spirax Sarco application information sheet. The obscuration factor (Fo) is a mathematical correction for the area inside the pipe which is obstructed by the S-Turbo-Bar stem and rotor.

#### 4. Profile Factor (Fp):

The profile factor (Fp) is also found on the Spirax Sarco application information sheet. The profile factor (Fp) is a mathematical correction for relating the rotor velocity (point velocity) to an average pipeline velocity.

#### 5. System K-Factor (Ks):

The system K-factor (Ks) is used to convert the rotor input frequency (Ft) to flow rate in appropriate engineering units. The units may be in pulses/gallons, pulses/SCF, pulses/pounds, etc. Ks is found on the Spirax Sarco application information sheet. The mathematical equations used to arrive at the Ks value follow.

### 8.3 Mathematical Equations Used to Find the Ks Value

#### 8.3.1 Liquid

$$K_s (\text{pulses / ft}^3) = \frac{K_f}{A \cdot F_o \cdot F_p}$$

or

$$K_s (\text{pulses / gallons}) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot 7.48}$$

or

$$K_s (\text{pulses / pounds}) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot \rho}$$

or

$$K_s (\text{pulses / Btus}) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot \rho \cdot (h_1 - h_2)}$$

Where:

Ks = System K-factor

Kf = Rotor cal. constant in pulse/ft (available from the Spirax Sarco application or rotor calibration sheet)

A = Pipeline cross-sectional area in ft<sup>2</sup>

Fo = Obscuration factor - available from the Spirax Sarco application information sheet

Fp = Profile factor - available from application information sheet

r = Density of liquid in lbs/ft<sup>3</sup>

h1 = Enthalpy of supply line in chilled or hot water systems (Btus/pounds)

h2 = Enthalpy of return line in chilled or hot water systems (Btus/pounds)

#### 8.3.2 Steam

$$K_s (\text{pulses / pounds}) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot \rho}$$

or

RTD

Resistance Output

Where:

Ks = System K-factor

Kf = Rotor cal. constant in pulses/ft (available from the Spirax Sarco application or rotor calibration sheet)

A = Pipeline cross-sectional area in ft<sup>2</sup>

Fo = Obscuration factor - available from the Spirax Sarco application information sheet

Fp = Profile factor - available from the Spirax Sarco application information sheet

r = Density of steam in lbs/ft<sup>3</sup>

hg = Enthalpy of steam in BTUs/pounds

### 8.3.3 Natural Gas and Other Ideal Gases

$$K_s \left( \text{pulses / actual ft}^3 \right) = \frac{K_f}{A \cdot F_o \cdot F_p}$$

$$K_s \left( \text{pulses / std. ft}^3 \right) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot F_{pv}^2} \cdot \left[ \frac{14.73}{P_a} \cdot \frac{T_a}{520} \right]$$

$$K_s \left( \text{pulses / pounds} \right) = \frac{K_f}{A \cdot F_o \cdot F_p \cdot \rho}$$

Where:

$K_s$  = System K-factor

$K_f$  = Rotor cal. constant in pulses/ft (available from the Spirax Sarco application or rotor calibration sheet)

$A$  = Pipeline cross-sectional area in  $\text{ft}^2$

$F_o$  = Obscuration factor - available from the Spirax Sarco application information sheet

$F_p$  = Profile factor - available from the Spirax Sarco application information sheet

$T_a$  = Absolute line temperature in  $^{\circ}\text{Rankine}$   
 $^{\circ}\text{R} = (^{\circ}\text{F} + 460)$

$P_a$  = Absolute line pressure in psia

psia = (psig + local barometric pressure)

$r$  = Density of natural gas in  $\text{lbs}/\text{ft}^3$

$F_{pv}$  = Super compressibility factor

$$\text{Density} \left( \text{lbs} / \text{ft}^3 \right) = \frac{2.7 \cdot \text{SG} \cdot P_a}{T_a}$$

Where:

SG = Specific gravity of natural gas

$P_a$  = Same as above

$T_a$  = Same as above

### 8.4 Determining Flow Rate

Once the  $K_s$  has been determined, the following equation can be used to determine flow rate:

$$Q = \frac{F_t}{K_s} \cdot T_b$$

Where:

$Q$  = Flow rate in appropriate engineering units

$F_t$  = Turbine flowmeter frequency in Hz (pulses/sec)

$K_s$  = System K-Factor (equations 1 thru 10)

$T_b$  = Time base

(sec;  $T_b=1$ )

(min;  $T_b=60$ )

(hour;  $T_b=3,600$ )

(day;  $T_b=86,400$ )

#### Note:

The values of  $F_o$  and  $F_p$  in the application information sheets are based on actual operating conditions. If conditions such as pipe size, flow rate, pressure, temperature, density (major elements) change, new values should be obtained from Spirax Sarco. In such applications, a Spirax Sarco flow processor, such as an S-FP-93 or FP-100, may be used to automatically compute the values for  $F_o$  or  $F_p$ .

**8.5 Liquid Application Examples****8.5.1 Example 1**

The S-Turbo-Bar referenced in the sample application sheet on page 45 shows an output of 135 Hz. Determine flow rate in ft<sup>3</sup>/min.

**Answer:**

Step 1. Find Ks in pulses/ft<sup>3</sup>. Ks for liquid in pulses/ft<sup>3</sup> is calculated as:

$$Ks(\text{pulses / ft}^3) = \frac{Kf}{A \cdot Fo \cdot Fp}$$

$$Ks(\text{pulses / ft}^3) = \frac{23.1254}{2.7917 \cdot 0.9901 \cdot 0.8267}$$

$$Ks = 10.12 \text{ pulses/ft}^3$$

Step 2. Find the flow rate. Flow rate for liquid in ft<sup>3</sup>/min is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{135}{10.12} \cdot 60$$

$$Q = 800.39 \text{ ft}^3/\text{min}$$

**8.5.2 Example 2**

The S-Turbo-Bar referenced in the sample application sheet on page 45 shows an output of 135 Hz. Determine flow rate in gal/min.

**Answer:**

Step 1. Find Ks in pulses/gallons. Ks for liquid in pulses/gallon is already calculated on the sample application sheet as:

$$Ks = 1.3528 \text{ pulses/gallons.}$$

Step 2. Find the flow rate. Flow rate for liquid in gal/min is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{135}{1.3528} \cdot 60$$

$$Q = 5,987.58 \text{ gal/min}$$

**8.5.3 Example 3**

The S-Turbo-Bar referenced in the sample application sheet on page 45 shows an output of 135 Hz. Determine flow rate in pounds/hr.

**Answer:**

Step 1. Find Ks in pulses/pounds. Ks for liquid in pulses/pounds is calculated as:

$$Ks(\text{pulses / pounds}) = \frac{Kf}{A \cdot Fo \cdot Fp \cdot \rho}$$

$$Ks(\text{pulses / pounds}) = \frac{23.1254}{2.7917 \cdot 0.9901 \cdot 0.8267 \cdot 62.42}$$

$$Ks = 0.1621 \text{ pulses/pounds}$$

Step 2. Find flow rate. Flow rate for liquid in pounds/hr is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{135}{0.1621} \cdot 3,600$$

$$Q = 2,998,149.29 \text{ pounds/hr}$$



## 8.5.4 Sample Application Information Sheet for Water

**Spirax Sarco, Inc.**  
**1150 Northpoint Blvd.**  
**Blythewood, SC 29016**  
**PH: 803-682-7060**

**Work Order #: C111111-001**  
**Date: 2/15/92**  
**Purchase Order: 2235**  
**Data Entry: By B.G.**  
**Tag #:**

**\*Application Information\***

Customer: Sample  
 Address:  
 Person:  
 Comments:

Fluid: Water

Pipe Inside Diameter: 22.624 in

Area: 2.7917E+00 sq. ft.

	<u>min</u>	<u>nom</u>	<u>max</u>	<u>units</u>
Pressure	110	110	110	psig
temperature	42	42	52	deg F
Density	62.4229	62.4229	62.4229	lb/cu ft
Flow Rate	0	4000	8000	US gallons/min
Velocity	0	3.192339	6.384677	ft/sec
Viscosity		1.5057		c-poise
REYNOLDS NUMBER	0	371059	742118	

Barometric Pressure: 14.7 psia

**\* Rotor Data \***

Rotor Model: 150-040-U-CSJ (L1)

Serial #:C111111-001

Cal. Number: 0

Cal. Constant. Kf (Mean lin-Inp): 22.51 pulses per foot (Nom-Adj): 23.1254

System K Factor (Ks) : 1.3528E+00 pulses per US gallons

Obscuration Factor (Fo): .9901067

Profile Factor (Fp): .8267239

Probe Insertion Depth: 5.656 in 1/4 ID- position

Max. Rotor Velocity: 7.800033 ft/sec

**\* Electrical Scaling \***

Electronics Model : PA1/2

Serial #

Maximum Scaling Frequency (hz): 180.0

Full-Scale Setting: 8,000 US gallons per min (gpm)

**8.6 Steam Application Examples****8.6.1 Example 1**

The S-Turbo-Bar referenced in the sample application sheet on page 47 shows an output of 1,000 Hz at 165 psig. Determine flow rate in pounds/hr.

**Answer:**

Step 1. Find Ks in pulses/pounds. Ks for steam in pulses/pounds is calculated as:

$$Ks(\text{pulses / pounds}) = \frac{Kf}{A \cdot Fo \cdot Fp \cdot \rho}$$

$$\rho(\text{at 165 psig}) = .3944 \text{ pounds/ft}^3$$

$$Ks(\text{pulses / pounds}) =$$

$$\frac{12.6601}{0.5476 \cdot 0.9557 \cdot 0.76208 \cdot 0.3944}$$

**Ks = 80.48 pulses/pounds**

Step 2. Find flow rate. Flow rate for steam in pounds/hr is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{1,000}{80.48} \cdot 3,600$$

**Q = 44,731 pounds/hr**

**8.6.2 Example 2**

The S-Turbo-Bar referenced in the sample application sheet on page 47 shows an output of 1,000 Hz at 165 psig. Determine the heat content flow rate in Btus/hr.

**Answer:**

Step 1. Find Ks in pulses/BTUs. Ks for steam in pulses/BTUs is calculated as:

$$\frac{RTD}{\text{Resistance Output}}$$

$$\rho(\text{at 165 psig}) = .3944 \text{ pounds/ft}^3$$

$$hg(\text{165 psig: from steam tables}) = 1196.9 \text{ Btus/lb}$$

Ks(pulses / Btus) =

$$\frac{12.6601}{0.5476 \cdot 0.9557 \cdot 0.7628 \cdot 0.3944 \cdot 1196.9}$$

**Ks = 0.06718 pulses/Btus**

Step 2. Find flow rate. Flow rate for steam in BTUs/hr is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{1,000}{0.06718} \cdot 3,600$$

**Q = 53,587,377.2 BTUs/hr**

## 8.6.3 Sample Application Information Sheet for Steam

**Spirax Sarco, Inc.**  
**1150 Northpoint Blvd.**  
**Blythewood, SC 29016**  
**PH: 803-682-7060**

**Work Order #: C111111-001**  
**Date: 2/15/92**  
**Purchase Order: 2235**  
**Data Entry: By B.G.**  
**Tag #:**

**\*Application Information\***

Customer: Sample  
 Address:  
 Person:  
 Comments:

Fluid: Saturated Steam  
 Pipe Inside Diameter: 10.02 in      Area: 5.4760 E-01 sq ft

	<u>min</u>	<u>nom</u>	<u>max</u>	<u>units</u>
Pressure	165	165	165	psig
temperature	372.7683	372.7683	372.7683	deg F
Density	0.3944	0.3944	0.3944	lb/cu ft
Flow Rate	0	25000	50000	pounds/hr
Velocity	0	32.15131	64.30262	ft/sec
Viscosity		0.0162		c-poise
REYNOLDS NUMBER	0	972009.6	1944019	

Barometric Pressure: 14.7 psia

**\* Rotor Data \***

Rotor Model: 150-030-U-DEV (G3)  
 Serial #:C111111-002      Cal. Number: 121  
 Cal. Constant. Kf (Mean lin-Inp): 12.563 pulses per foot (Nom-Adj): 12.6601  
 System K Factor (Ks) : 8.0476E+01 pulses per pound  
 Obscuration Factor (Fo): .9557077  
 Profile Factor (Fp): .762088  
 Probe Insertion Depth: 5.01 in centerline position  
 Max. Rotor Velocity: 88.28734 ft/sec

**\* Electrical Scaling \***

Electronics Model : PA1/2      Serial #  
 Maximum Scaling Frequency (hz): 1118.0  
 Full-scale Setting: 8,000 US gallons per min (gpm)  
 Scaling based on 179.7 psia      372.7683 deg F      .3944355 lb/cu ft

**8.7 Natural Gas Application Examples****8.7.1 Example 1**

The S-Turbo-Bar referenced in the sample application sheet on page 49 shows an output of 800 Hz. Determine flow rate in actual ft<sup>3</sup>/min.

**Answer:**

Step 1. Find Ks in pulses/ft<sup>3</sup>. Ks for natural gas in pulses/ft<sup>3</sup> is calculated as:

$$Ks \left( \text{pulses / actual ft}^3 \right) = \frac{Kf}{A \cdot Fo \cdot Fp}$$

$$Ks \left( \text{pulses / actual ft}^3 \right) = \frac{8.10411}{0.7854 \cdot 0.9824 \cdot 0.7923}$$

$$Ks = 13.257 \text{ pulses/ft}^3$$

Step 2. Find flow rate. Flow rate for natural gas in pulses/ft<sup>3</sup> is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{800}{13.257} \cdot 60$$

$$Q = 3,620.7 \text{ actual ft}^3/\text{min}$$

**8.7.2 Example 2**

The S-Turbo-Bar referenced in the sample application sheet on page 49 shows an output of 800 Hz. Determine flow rate in std ft<sup>3</sup>/min.

**Answer:**

Step 1. Find Ks in pulses/gallons. Ks is already calculated on the application sample sheet as, Ks= 0.71157.

Step 2. Find flow rate. Flow rate for natural gas in std ft<sup>3</sup>/min is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{800}{0.71157} \cdot 60$$

$$Q = 67,456.47 \text{ std ft}^3/\text{min}$$

**8.7.3 Example 3**

The S-Turbo-Bar referenced in the sample application sheet on page 49 shows an output of 800 Hz. Determine flow rate in pounds/min.

**Answer:**

Step 1. Find Ks in pulses/pounds. Ks for natural gas in pulses/pounds is calculated as:

$$Ks \left( \text{pulses / pounds} \right) = \frac{Kf}{A \cdot Fo \cdot Fp \cdot \rho}$$

$$\rho \left( \text{pounds / ft}^3 \right) =$$

$$\frac{2.7 \cdot SG \cdot Pa}{Ta} = \frac{2.7 \cdot 0.667 \cdot 279.73}{530}$$

$$\rho = 0.8555 \text{ pounds/ft}^3$$

$$Ks \left( \text{pulses / pounds} \right) =$$

$$\frac{8.10411}{0.7854 \cdot 0.9824 \cdot 0.7923 \cdot 0.8555}$$

$$Ks = 15.495 \text{ pulses/pounds}$$

Step 2. Find flow rate. Flow rate for natural gas in pounds/min is calculated as:

$$Q = \frac{Ft}{Ks} \cdot Tb$$

$$Q = \frac{800}{15.495} \cdot 60$$

$$Q = 3,097.77 \text{ pounds/min}$$

## 8.7.4 Sample Application Information Sheet for Natural Gas

Spirax Sarco, Inc.  
 1150 Northpoint Blvd.  
 Blythewood, SC 29016  
 PH: 803-682-7060

Work Order #: C111111-001  
 Date: 2/15/92  
 Purchase Order: 2235  
 Data Entry: By B.G.  
 Tag #:

**\*Application Information\***

Customer: Sample  
 Address:  
 Person:  
 Comments:

Fluid: Natural Gas (AGA 3)  
 Pipe Inside Diameter: 12 in

Area: 7.8540 E-01

	<u>min</u>	<u>nom</u>	<u>max</u>	<u>units</u>
Pressure	265	265	435	psig
temperature	70	70	70	deg F
Density	0.8555	0.8555	1.3754	lb/cu ft
Flow Rate	16,666	50,000	100,000	std cu f t/min
Velocity	18.98434	56.95302	70.84617	ft/sec
Viscosity		0.0105		c-poise
REYNOLDS NUMBER	2289253	6867759	8543083	

Barometric Pressure: 14.7 psia

Base pressure: 14.73

Base temperature: 60 deg F

Supercompressibility (FPV): 1

Specific Gravity: .6

**\* Rotor Data \***

Rotor Model: 150-020-U-DEV (G3)

Serial #:C111111-003

Cal. Number: 0

Cal. Constant. Kf (Mean lin-Inp): 8.183 pulses per foot (Nom-Adj): 8.104114

System K Factor (Ks) : 7.1157E-01 pulses per std cu ft

Obscuration Factor (Fo): .9824475

Profile Factor (Fp): .7922764

Probe Insertion Depth: 3 in 1/4 ID- position

Max. Rotor Velocity: 91.01862 ft/sec

**\* Electrical Scaling \***

Electronics Model : PA1/2

Serial #

Maximum Scaling Frequency (hz): 1186.0

Full-scale Setting: 6,000,000 std cu ft per hr

Scaling based on: 279.7 psia 70 deg F

**8.8 Sample Rotor Calibration Sheet**

**Spirax Sarco, Inc.**  
**1150 Northpoint Blvd.**  
**Blythewood, SC 29016**  
**PH: 803-682-7060**

**Work Order #:**  
**Date:**  
**Customer:**  
**Purchase Order:**  
**Data Entry By:**  
**Calibration #:**  
**Serial # : I002**  
**150-040-CSJ**

**150 Liquid Rotor Calibration**

Pipe dia =  inches  
 Area =  sq. feet

LBS.	TIME	PULSES	S-TEMP °F	density lbs/cu-ft	freq Hz	avg vel. Ft/Sec	Reynolds Number	Profile Factor	Obscur. Factor	Local Vel Ft/sec	Local K pulse/ft	% DEV. MEAN
200	82.49	2014.00	68.00	62.33	24.42	0.85	18960	0.8049	0.7982	1.32	18.50	non-lin
200	52.44	2072.00	68.00	62.33	39.51	1.33	29825	0.8086	0.7982	2.07	19.12	0.72%
200	34.83	2069.00	68.00	62.33	59.40	2.01	44905	0.8118	0.7982	3.10	19.16	0.97%
500	59.00	5055.00	68.00	62.33	85.68	2.96	66273	0.8147	0.7982	4.56	18.80	-0.97%
500	50.93	5060.00	68.00	62.33	99.35	3.43	76774	0.8158	0.7982	5.27	18.84	-0.74%
500	28.49	5047.00	68.00	62.33	177.15	6.14	137244	0.8200	0.7982	9.38	18.89	-0.49%

Mean =

freq Hz	Local Vel ft/sec
24.42	1.32
39.51	2.07
59.40	3.10
85.68	4.56
99.35	5.27
177.15	9.38
K-Factor	18.98
	pulses/ft
Serial #	I002


# Section 9: Maintenance and Troubleshooting

## 9.1 General Information


If you are experiencing difficulties with your S-Turbo-Bar flowmeter, use the following information to identify and solve problems.

## 9.2 No Output


1. Verify wiring is in accordance with all wiring diagrams in Section 5: Electrical Installation.
2. Check supply power to the preamplifier. Supply voltage should be 24 VDC.
3. For S-Turbo-Bar flowmeters using either the PAQ or P2Q2 preamplifiers, check loop resistance. Make sure the total load resistance does not exceed the values shown below:



4. Check the pickup coil for shorts— both across the coil and coil to ground. To do so, shut off power to the preamplifier and remove the coil wires from the preamp terminal. First, check for a short across the coil by attaching an ohm flowmeter to the pickup coil wires as shown below. The coil should have a nominal resistance of 300 ohms at ambient temperature. (Resistance will change with temperature). Zero or infinite resistance indicates a defective pickup.



Next, check for a coil to ground short. Using the same two wires from the previous example, hold one of the coil wires and make solid contact with one of the ohm flowmeter leads. Take the other ohm meter lead and touch it to the stem. The ohm meter should read infinite resistance. Zero resistance indicates a coil to ground short and the stem and coil assembly should be replaced. Repeat this step for the other coil wire as shown below.



5. Check the rotor for bearing drag or seizure. To do so, check by holding the rotor assembly between the thumb and forefinger while blowing on the rotor. If the bearings are worn the rotor may seize or spin poorly.
6. Check the rotor for bent blades or a bent yoke. All turbine blades are profiled for different flow conditions. Look for blade(s) which are clearly different from the factory profiled blades. The yoke, which houses the turbine, is usually damaged when the gate valve is inadvertently shut before the turbine is fully retracted. Over-inserting the rotor into the bottom of the pipe yields the same result. Be very careful when lowering and retracting the sensor.
7. Check the rotor for contamination. Look for debris sticking to the rotor blades. If the rotor stops spinning, the blades may be unbalanced by debris. A contaminated blade will always stop or unbalance the rotor. To remove heavy contaminants from the rotor or bearings, use an ultrasonic cleaner.
8. Check the rotor for magnetization. If a rotor has been left on a flowmeter, which is out of service, or in flows without enough kinetic energy to spin the rotor, the blade nearest the magnetic pickup will become over-magnetized. As a result, the rotor spins unevenly or does not spin at all. To demagnetize a rotor, a small magnet and oscilloscope is needed. Follow the steps outlined below:
  - a. Disconnect the coil wires from the preamplifier terminal block.
  - b. Connect the ground lead of the oscilloscope to DC common, terminal 3.
  - c. Connect the scope probe to the test point in the lower left hand corner of the terminal block. This will yield a sine wave. If a square wave is desired, connect the scope probe to terminal 2.
  - d. Blow hard on the rotor until it spins. The oscilloscope should display sine waves. If the rotor is magnetized, the scope tracing should resemble:
 

The figure shows an oscilloscope screen with a grid. The waveform is highly irregular and jagged, with varying amplitudes and frequencies, which is characteristic of a magnetized rotor. It does not resemble a smooth sine wave.
  - e. Apply air flow sufficient to spin the rotor steadily at about 3,000 - 4,000 RPM. Using the south (negative) pole of a strong (approximately 30 million gauss) permanent magnet, slowly move the magnet close to the rotor, about 1/4" away, then back to 2" away. Repeat several times, but do not touch the blades of the rotor with the magnet. This yields uniform polarity.
10. Check the preamplifier for proper operation and scaling, according to Section 5: Electrical Installation.
11. Contact Spirax Sarco or your Spirax Sarco sales representative.

**9.3 Analog Output Equals 0 mA**

1. Verify wiring is in accordance with the power and wiring diagrams in Section 5: Electrical Installation.
2. Check the power supply voltage.
3. For S-Turbo-Bar flowmeters using the PAQ or P2Q2 preamplifiers, check loop resistance. Make sure the total loop resistance does not exceed 9 volts.
4. Check the voltage at the flowmeter.
5. Contact Spirax Sarco or your Spirax Sarco sales representative.



**9.4 Analog Output less than 4 mA**

1. Verify wiring is in accordance with the power and wiring diagrams in Section 4: Electrical Installation..
2. Check the power supply voltage.
3. For S-Turbo-Bar flowmeters using the PAQ or P2Q2 preamplifiers, check loop resistance. Make sure the total loop resistance does not exceed 9 volts.
4. Check the voltage at the flowmeter.
5. Verify the analog zero and span calibration.
6. Contact Spirax Sarco or your Spirax Sarco sales representative.

**9.5 Inaccurate Output**

1. Verify the piping installation has allowed for the required straight pipe run. See 3.2 Straight Run Pipe, p. 7.
2. Verify flow is within the range of the rotor. See Table below.

English Units		Liquid			Gas or Steam				
Pipe Size	Rotor	L1 (40° pitch)	G1 (40° pitch)	G2 (30° pitch)	G3 (20° pitch)	G4 (15° pitch)	G5 (10° pitch)	G6 <sup>1</sup> (5° pitch)	
All	V <sub>max</sub> (ft/sec)	30	55	70	85	115	145	175	
3 - 5"	V <sub>lin</sub> (ft/sec)	1.4	3.19 / √ρ	3.98 / √ρ	4.52 / √ρ	5.84 / √ρ	6.91 / √ρ	6.10 / √ρ	
	V <sub>min</sub> (ft/sec)	0.5	1.94 / √ρ	2.26 / √ρ	2.42 / √ρ	3.85 / √ρ	4.57 / √ρ	N/A	
6"	V <sub>lin</sub> (ft/sec)	1.5	2.00 / √ρ	2.27 / √ρ	2.52 / √ρ	3.78 / √ρ	4.78 / √ρ	5.53 / √ρ	
	V <sub>min</sub> (ft/sec)	0.6	1.23 / √ρ	1.63 / √ρ	1.95 / √ρ	2.84 / √ρ	3.47 / √ρ	N/A	
8" +	V <sub>lin</sub> (ft/sec)	1.6	1.50 / √ρ	1.90 / √ρ	2.18 / √ρ	3.00 / √ρ	3.54 / √ρ	5.00 / √ρ	
	V <sub>min</sub> (ft/sec)	0.7	1.00 / √ρ	1.31 / √ρ	1.40 / √ρ	2.19 / √ρ	2.81 / √ρ	N/A	
Metric Units		Liquid			Gas or Steam				
All	V <sub>max</sub> (m/sec)	9	17	21	26	35	44	53	
75-125 mm	V <sub>lin</sub> (m/sec)	0.4	3.89 / √ρ	4.86 / √ρ	5.51 / √ρ	7.12 / √ρ	8.43 / √ρ	7.44 / √ρ	
	V <sub>min</sub> (m/sec)	0.2	2.37 / √ρ	2.76 / √ρ	2.95 / √ρ	4.70 / √ρ	5.57 / √ρ	N/A	
150 mm	V <sub>lin</sub> (m/sec)	0.5	2.44 / √ρ	2.77 / √ρ	3.07 / √ρ	4.61 / √ρ	5.83 / √ρ	6.75 / √ρ	
	V <sub>min</sub> (m/sec)	0.2	1.50 / √ρ	2.00 / √ρ	2.38 / √ρ	3.46 / √ρ	4.23 / √ρ	N/A	
200 mm +	V <sub>lin</sub> (m/sec)	0.5	1.83 / √ρ	2.32 / √ρ	2.67 / √ρ	3.66 / √ρ	4.32 / √ρ	6.10 / √ρ	
	V <sub>min</sub> (m/sec)	0.2	1.22 / √ρ	1.60 / √ρ	1.71 / √ρ	2.67 / √ρ	3.43 / √ρ	N/A	


Where:

- V<sub>max</sub> = maximum velocity of fluid [ft/sec (m/sec)]
- V<sub>lin</sub> = minimum velocity of fluid at which rotor response is linear [ft/sec (m/sec)]
- V<sub>min</sub> = minimum measurable velocity of fluid [ft/sec (m/sec)]
- ρ = density of fluid [lbs/ft<sup>3</sup> (kg/m<sup>3</sup>)
- N/A = no application

3. Check pickup coil for intermittent resistance. Follow step 4 in 9.2 No Output, p. 51.
4. Verify the correct K-factor has been used.


5. Check the quality of the rotor signal. To do so, shut off power to the preamplifier and remove the coil wires from the preamp terminal. Attach an oscilloscope to the pickup coil wires as described in step 4 under 9.2 No Output, p. 51. Set the scope to horizontal and vertical sweep, displaying ten cycles of rotor output. The accompanying illustrations depict oscilloscope tracings characteristic of normal and damaged rotors.

**9.5.1 Normal Rotor**




The normal signal from the magnetic pickup coil is a sine wave. For a normal ten-blade rotor, there are ten identical sinewaves per revolution

**9.5.2 Bent Blades**




Bent blades display one or more cycles which lean away from perpendicular or drop below the center line.

**9.5.3 Missing Rotor**




A rotor missing a blade produces an abnormal wave form or cycle. Typically, the wave pattern will have a gap left from the missing blade.

**9.5.4 Magnetized Rotor**




A rotor with residual magnetism produces an erratic signal which will appear as if a high frequency signal has been combined with a longer, lower frequency signal.

**9.5.5 Overranged Flowmeter**



Excessive flow velocity can cause the rotor to overspeed. The sine wave of an over-ranged rotor looks as if several sine waves were superimposed on each other each wave slightly offset from the other.

**9.5.6 Chatter**



Worn bearings or a bent yolk can cause chatter. The wave form of chatter will show the horizontal sweep pulled down from the center.

6. Check for electrical noise according to Section 5: Electrical Installation.
7. Check the preamplifier for proper scaling and operation according to Section 5: Electrical Installation.
8. Contact Spirax Sarco or your Spirax Sarco sales representative.

# Section 10: Model and Suffix Codes

Category	Description	Suffix Codes	S-700 Only
<i>Model</i>	Liquid or gas service, 400 °F (204 °C) Steam or hot water service, 400 °F (204 °C) Liquid, gas or steam service, 600 °F (315 °C) Liquid or gas service, 400 °F (204 °C) Liquid, gas or steam service, 752 °F (400 °C)	S-TMP-600 ... .. S-TMP-60S ... .. S-TMP-700 ... .. S-TMP-800 ... .. S-TMP-960 ... ..	...
<i>Connection</i>	2", male NS-PT with isolation valve & Thread-o-Let (XX=03-70" pipe)(model 600 only) 2", male NS-PT (models 700, 800 only) 2", 150# flange (all models except 600) 2", 300# flange (all models except 600 and 800) 2", 600# flange (all models except 600 and 800) 2", 900# flange (all models except 600 and 800) 2", 1500# flange (models 910 and 960 only)	... VXX ... .. ... 2NS-PT ... .. ... 2F150 ... .. ... 2F300 ... .. ... 2F600 ... .. ... 2F900 ... .. ... 2F1500 ... ..	...
<i>Rotor</i>	Liquid, 30 ft/sec maximum( 9 m/sec)(40° Pitch) Gas or steam, 55 ft/sec maximum (17 m/sec) (40° Pitch) Gas or steam, 70 ft/sec maximum (21 m/sec) (30° Pitch) Gas or steam, 85 ft/sec maximum (26 m/sec) (20° Pitch) Gas or steam,115 ft/sec maximum (35 m/sec) (15° Pitch) Gas or steam,145 ft/sec maximum (44 m/sec) (10° Pitch) Gas or steam,175 ft/sec maximum (53 m/sec) (05° Pitch) <sup>1</sup> For bidirectional rotor	... .. L1 ... .. ... .. G1 ... .. ... .. G2 ... .. ... .. G3 ... .. ... .. G4 ... .. ... .. G5 ... .. ... .. G6 ... .. ... .. XXB ... ..	...
<i>Electronics</i>	EZ Logic with local rate and total <sup>3</sup> Remote, only available with LOC-TOT option <sup>4</sup> FM Approval <sup>5</sup>	... .. LOC-TOT ... .. ... .. RMT ... .. ... .. FM ... ..	...
<i>Pressure Transmitter</i>	No pressure transmitter Pressure transmitter with scaled preamplifier: 0 - 50 psi gauge (0 - 3.44 barg) 0 - 100 psi gauge (0 - 6.89 barg) 0 - 150 psi gauge (0 -10.34 barg) 0 - 200 psi gauge (0 -13.79 barg) 0 - 250 psi gauge (0 -17.24 barg) 0 - 500 psi gauge (0 -34.47 barg) 0 -1000 psi gauge (0 -68.95 barg) Transmitters can be scaled to accommodate special requests and bar scaling (see below) <sup>6</sup>	... .. XX ... .. ... .. 50 ... .. ... .. 100 ... .. ... .. 150 ... .. ... .. 200 ... .. ... .. 250 ... .. ... .. 500 ... .. ... .. 1000 ... .. ... .. PXX ... ..	...
<i>temperature Sensor or Transmitter</i>	No temperature transmitter RTD only S-TEMP. transmitter with scaled preamplifier: 32 to 68 °F 0 to 250 °F -40 to 150 °F 212 to 400 °F 212 to 800 °F -17.7 to 121.1 °C -40 to 65 °C 100 to 204 °C 100 to 426 °C Transmitters can be scaled to accommodate special requests and bar scaling (see below) <sup>6</sup>	... .. XXX ... .. ... .. RTD ... .. ... .. T09 ... .. ... .. T10 ... .. ... .. T11 ... .. ... .. T12 ... .. ... .. T13 ... .. ... .. T20 ... .. ... .. T21 ... .. ... .. T22 ... .. ... .. T23 ... .. ... .. TXX ... ..	...
<i>Extended SS-TEM</i>	None (standard length) 1' extension (not available on 600 or 60S)* 2' extension (gas or steam applications only)(not available on 600 or 60S)*	... .. XX ... .. ... .. E1 ... .. ... .. E2 ... ..	...
<i>Pick-up Coil Wires (Internal)</i>	<b>S-TMP-700 Only:</b> Teflon, -200 to 400 °F, (-129 to 204 °C) <b>S-TMP-700 Only:</b> Fiberglass, 150 to 600 °F, (65 to 316 °C)	... .. T ... .. ... .. F ... ..	T F

\*Requires minimum 2" tap hole size

**Notes:**

- The G6 is the only available 1" shrouded rotor. Not available for use with bidirectional meters.
- Not available with European CE Mark.
- Unidirectional only. Unit has 4-20 mA and frequency output.
- Remote mount electronics are required for high process temperatures. The standard remote mount option comes with 30' feet of cable.
- Certified by FM for Class I, Division 2, Groups A, B, C, D; Class II,III, Division 2, Groups F,G. FM approval with only LOC-TOT and RMT electronics options. If FM is required, use RTD option only for temperature selection.
- Special transmitter scaling is available. Please note scaling range below model code with ordering. If no special scaling is indicated, transmitter will be scaled per model code.

**EXAMPLE:** S-TMP-910-2F900-G3-PA1-0200-T12-E1  
(for bidirectional meters): S-TMP-910-2F900-G3B-PA2-0200-T12-E1









EMCO is the brand of precision flow meters for liquid, gas, and steam applications, accommodating a wide range of pipe sizes. Field proven for over 40 years, the EMCO product line offers solutions for measurement, including industrial inline vortex, industrial insertion vortex and turbine, and variable area flow products. EMCO products provide a wide range of metering solutions to diverse industries, including the military, hospitals, universities, and many Fortune 500 companies.

Our aim is to provide a metering solution that helps our customers achieve operational improvement through their production capability, usually in the form of reduced energy usage, improved product quality, lower emissions and greater production throughout. Reducing emissions, carbon footprint, and your company's impact on the environment is our goal. Not only will this have a strong social and environmental impact but also a positive economic impact today and well into the future.



For more information contact:  
Spirax Sarco, Inc.  
2150 Miller Drive, Longmont, CO 80501  
T: 800.356.9362 or 303.682.7060  
F: 303.682.7069

[www.spiraxsarco.com/us](http://www.spiraxsarco.com/us)